

# DRILLED SHAFT INSPECTION LOG



Unique ID:

Status:

Date:

File No:

Sub File No:

Project No:

Road No:

Road Info:

Contractor:

Bent No:  Shaft No:  Station No:  Offset:  ' -  "

Type of Drilling Fluid:  Shaft Plumbness Check/4 ft:

DS Loc. Variance at Top:  Rebar Cage: Proper # Vert. Bars

Bottom Cleanout Method:  Proper # Horiz. Bars

Date/Time Final Cleanout:  Side Spacers

Shaft Bottom Elevation:  Bottom Spacers

Est. Shaft Bottom Diam:  Ties & Connections

Note: Specification Tolerances Location Variances at Top = 3 inches Max.  
Vertical (Plumbness) = 1 inch per 4 ft. Max.

Inspected By:

Method of Inspection:

Pre-Rebar Test:

Pre-Concrete Test:

Date/Time Started:

Date/Time Started:

Date/Time Ended:

Date/Time Ended:

### NORTH\*

Prior to rebar:

Prior to concrete:

### WEST\*

Prior to rebar:

Prior to concrete:

### CENTER

Prior to rebar:

Prior to concrete:

### EAST\*

Prior to rebar:

Prior to concrete:

### SOUTH\*

Prior to rebar:

Prior to concrete:

\*Based on compass direction

Results:

Comments or Recommendations:

Contractor Drill Shaft Foreman

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

SCDOT Inspector

Signature: \_\_\_\_\_ Date: \_\_\_\_\_