


Test Location Information:

Exploration: B-40 Date: 10/2/2008
Surface El.: 2.3 feet Engineer: MLE
Test Depth: 33 feet
Test El.: -30.7 feet

Soil Data:**Summary of Test Results:**

Liquid Limit:	71		<u>Uncorrected</u>	<u>Corrected</u>	<u>Chandler Correction Factor</u>
Plastic Limit:	47	Undisturbed S_u (psf):	360	299	0.83
Plasticity Index:	24	Remolded S_u (psf):	50	42	<u>Sensitivity</u>
%-Passing 200:	93	Effective Vertical Stress (psf):	1,076	1,076	7.2
Classification:	MH	S_u / p'_o	0.33	0.28	
Moisture Content:	148				

*Note: Soil data was gathered from B-39 SPT at a depth of 23.5 ft.

Field Vane Shear Test Results

www.smeinc.com

620 Wando Park Boulevard
Mt. Pleasant, South Carolina 29464
Tel 843.884.0005
Fax 843.881.6149

FIELD VANE SHEAR TEST REPORT | 1 of 3

Project No.: 1131-08-554
Project Name: Port Access Road
Location: Charleston, SC
Client: SCDOT