

RIGID BARRIER ADJACENT TO WALL

NOTES:

PROVIDE MATERIALS IN ACCORDANCE WITH RIGID BARRIER STANDARD DRAWINGS.

① PROVIDE REINFORCING AS REQUIRED BY STANDARD DRAWING 805-805-00 OR 805-805-05.

② PROVIDE EMBEDMENT BASED ON DISTANCE BETWEEN EXPANSION JOINTS IN ACCORDANCE WITH STANDARD DRAWING 805-805-00 or 805-805-05.

③ BACK FACE OF BARRIER MAY BE CAST VERTICAL INSTEAD OF SLOPING AS SHOWN. MAINTAIN STANDARD REINFORCING COVER. SLOPE THE CLASS 2500 CONCRETE CAP TO DRAIN AWAY FROM FACE OF WALL.

FOR COARSE AGGREGATE BACKFILL, USE AGGREGATE № 5, № 57, № 67, or № 6M.

FOR BARRIER EXPANSION JOINTS, COMPLETELY FILL THE JOINT WITH SPONGE RUBBER EXPANSION JOINT MATERIAL FROM QPL 81 FOR THE FULL HEIGHT OF BARRIER, INCLUDING FOUNDATION.