

**NON-CONFIDENTIAL DESIGN-BUILD QUESTIONS
Long Point Road Interchange Improvements
Project ID P041314 - Charleston County**

FINAL RFP - ROUND 9

Date Received: 3/17/2026

Response: 3/18/2026

CONTRACTOR					SCDOT		
Question No.	Category	Section	Page / Doc No.	Question/Comment	Discipline	Response	Explanation
1	Attach_B	Roadway	TPA 200-1	In R2_TPA 200-1, Typical Section #1 depicts noise walls immediately behind concrete roadside barrier attached to the proposed shoulder. Will SCDOT allow the noise walls for this section to be shifted further back away from the road, as depicted in the Conceptual Plans (which are for information only)? There is a safety benefit to moving these walls outside the clear zone.	Roadway	No_Revision	On Typical Section sheet 1 an alternative noise wall location inset detail has been provided. Please clarify if this detail is unclear in any way.
2	RFP	8	p. 47 / 696	We request that SCDOT revise the Milestone Schedule to push the dates back by 4 weeks for the Submittal of Technical Proposals, Technical Proposal Presentations, and Submittal of Cost Proposals to allow for teams to incorporate updated information included in Addendum #4 and recent Non-Confidential Question answers	PM	No_Revision	SCDOT appreciates the request and recognizes the importance of allowing sufficient time for teams to incorporate updates from Addendum #4 and recent Non-Confidential Question responses. At this time, the Milestone Schedule remains under review. This topic will be discussed further at the Open Forum on March 19 at 1:30 PM, and any decisions or updates will be communicated via a formal addendum.

